



Product Service

EC-Attestation of Conformity

No. N8 06 11 49965 002

Holder of Certificate: O-Sung Electric Machinery
Co., Ltd.

#111-3, Youngtae-Ri, Woollong-
413-813 Myun, Paju-City, Kyungki-Do
KOREA

Product: Low voltage switchgear combination
(Air Circuit Breaker with electronic
overcurrent protection)

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 73/23/EEC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0149486



Date, 2006-11-28



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



EC-Attestation of Conformity

No. N8 06 11 49965 002

Model(s): SB-616-D-3POLE, SB-616-D-4POLE
 SB-612-D-3POLE, SB-612-D-4POLE
 SB-610-D-3POLE, SB-610-D-4POLE
 SB-608-D-3POLE, SB-608-D-4POLE
 SB-606-D-3POLE, SB-606-D-4POLE

Parameters:	Rated operational voltage(Ue):	600 Va.c.
	Rated frequency:	50/60 Hz
	Utilization category:	B
	Rated insulation voltage(Ui):	1000 V
	Rated impulse withstand voltage(Uimp):	8 kV
	Number of poles:	3 or 4
	Rated current(In):	630/800/1000/1250/ 1600 A
	Rated service short-circuit Breaking capacity(Ics):	50 kA
	Rated ultimate short-circuit Breaking capacity(Icu):	50 kA

Tested according to: EN 60947-2:2003



Product Service

EC-Attestation of Conformity

No. N8 09 04 49965 003

Holder of Certificate: O-Sung Electric Machinery Co., Ltd.

#111-3, Youngtae-Ri, Woollong-Myun, Paju-City, Kyungki-Do 413-813
REPUBLIC OF KOREA

**Product: Low voltage switchgear combination
(Air Circuit Breaker with electronic overcurrent protection)**

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0112109

Date, 2009-04-08



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.



EC-Attestation of Conformity

No. N8 09 04 49965 003

**Model(s): SB-632-D-3POLE, SB-632-D-4POLE,
SB-625-D-3POLE, SB-625-D-4POLE,
SB-620-D-3POLE, SB-620-D-4POLE**

Parameters:

Rated operational voltage(Ue):	600 Va.c.
Rated frequency:	50/60 Hz
Utilization category:	B
Rated insulation voltage(Ui):	1000 V
Rated impulse withstand voltage(Uimp):	8 kV
Number of poles:	3 or 4
Rated current(In):	2000/2500/3200 A
Rated service short-circuit Breaking capacity(Ics):	65 kA
Rated ultimate short-circuit Breaking capacity(Icu):	65 kA
Rated short-time withstand current(Icw):	65 kA / 1 s

Tested according to: EN 60947-2:2006