



Ref. Certif. No.
SE-105492

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Automatic Transfer Switch
Name and address of the applicant	O-Sung Electric Machinery Co., Ltd. 136, Hantaemal-gil, Wollong-myeon, Paju-si Gyeonggi-do, Korea
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	OSEMCO
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	OSS-62-TN
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-6-1:2005+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	210500587SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Signature: *Quan Li*

Date: 16 July, 2021

Quan Li

Ratings and principal characteristics

Models:	OSS-62-TN
Ue: (V)	480V~
Ie: (A)	50, 80, 100, 125, 160, 200A
Poles:	2, 3, 4P
Frequency:	50/60Hz
Utilization Category:	AC-32B AC-31B
Class of equipment:	PC
Icw: (kA)	10kA/0,3s
Icm: (kA)	17kA
Ui: (V)	600V
Uimp: (kV)	8kV
Uc: (V)	220V~

Date: 16 July, 2021

Signature: *Amal*